

May 12, 2010

This report represents a preliminary determination of project requirements from various city departments. The report is based on project characteristics that you identified on the Site Plan and the Preliminary Application Form, and on your Pre-Application Site Visit (PASV). The city's goal is to provide you with as much information and assistance as possible prior to your permit application submittal. This coordinated list of requirements and decisions is a reference for creating a more complete submittal package to reduce the need for correction cycles that delay permit approval. The information in this report can also be used to develop a Street Improvement Plan (SIP) application for submittal to SDOT (see SDOT Client Assistance Memos 2200, 2201, 2211, 2212, 2213, and 2214).

Note: A preliminary assessment is being conducted on all land use projects as well as new construction projects. If you have a building project associated with your land use project, the preliminary assessment will not be repeated on the building project.

The applicant assumes full responsibility for determining all permit requirements and infrastructure improvements per applicable sections of the Seattle Municipal Code and the City of Seattle's Right-of-Way Improvement manual.

- Street use permits are required for all work in the right-of-way (see SDOT Client Assistance Memo 2100).
- If street improvements are required, you must obtain all necessary permits from SDOT.
- If an SIP is required, SDOT must accept your 90% complete SIP before DPD construction intake (see Client Assistance Memos 2200, 2206, 2209, 2211, 2213, and 2214).

Project Summary			
AP/Project No.	6247845	Ground Disturbance	Υ
Application Template	BLDG	PASV Required This Permit	Υ
Application Type	CONSTRUCTION AND DEVELOPMENT	Date PASV Completed	05/07/10
Category	SINGLE FAMILY / DUPLEX	PASV Done Under	
DPD Review Type	FULL	Permit Remarks	
Address	4501 Renton Ave S		
Location			
Zoning	L4	Applicant	JULIAN WEBER 4200 S RAYMOND ST SEATTLE WA 98118 (206) 953-1305
King County APN			
Permit Status	Initial Information Collected		
-	Construction of (15) SFR's on vacant property.	Applicant Email	julianrweber@gmail.com
		Linked AP/Project Nos.	
SDOT Project No	21485		

For detailed zoning information, click the King County APN number above, or visit http://web1.seattle.gov/dpd/parceldata/ to find zoning details about your address.

Pre-Application Site Visit (PASV) Report

Contact: Ede M Courtenay, (206) 733-9679, Ede.Courtenay@seattle.gov

PASV report requirements may be subject to additions, changes, or modifications by the department. The purpose of the report is to alert the applicant that there may be unusual or complex site conditions that trigger requirements from the department regarding this project. **The applicant is responsible for providing all**

required documents at the intake appointment. If you have questions about this report or the PASV process, please contact the DPD Site Development Team at (206) 684-8860.

Note: Any project application associated with the development site can utilize the results from this PASV if the application is accepted by DPD within 18 months of the above inspection date. After 18 months, the applicant must apply for another PASV. No extensions will be granted.

ECA Mapping Unit and Type

Non-ECA

Earth Disturbance

If excavation has the potential to encroach on adjacent property in order to facilitate construction activity, please provide documentation of consent from the adjacent property owner. Show area of proposed encroachment on the submitted drawings and detailed cross-sections.

If temporary cuts greater than 1h:1v will be required in order to facilitate construction activity, please provide a geotechnical engineer's verification that soil conditions allow cuts to stand unsupported. Include detailed cross sections.

If shoring will be required, please provide submittals by geotechnical and structural engineers and show the proposed system on the submitted drawings. Include detailed cross sections.

Existing ROW Conditions RENTON AVE S

Street conditions:

Asphalt paving

Curb conditions:

Curb adjacent to site

Concrete

Approximate curb height: 5" inches

A storm inlet is located <350 ft from the site and prior to crossing a public right of way. Corner of Renton and Oregon

S OREGON ST

Street conditions:

Asphalt paving

Curb conditions:

Curb adjacent to site

Concrete

A storm inlet is located <350 ft from the site and prior to crossing a public right of way.

Tree Protection

Existing trees appear to be shown accurately on the site plan

Construction Stormwater Control

All projects with earth disturbance, regardless of size, require temporary and permanent stormwater control in accordance with the Construction Stormwater Control (CSC) Technical Requirements Manual (DR 16-2009, Volume 2). The CSC Best Management Practices (BMPs) noted below can be found in the Construction Stormwater Control Technical Requirements Manual, available online and from DPD's Public Resource Center.

Show the following on the CSC/Post Construction Soil Amendment Plan:

Place compost socks, compost berms, filter fabric fencing, straw bales, straw wattles, or other approved perimeter control BMPs to eliminate construction stormwater runoff.

Show the location of a stabilized construction access to the site; show methods to eliminate uncontrolled conveyance of mud and dirt into the right of way (ROW).

Cover bare soil with compost blankets, straw, mulch, matting, or other approved equal to control construction stormwater runoff.

Cover stockpiles and bare slopes with compost blankets, tarps, matting or other approved equal to control construction stormwater runoff.

A First Ground Disturbance inspection is required before any ground disturbance related to this permit, including demolition, tree cutting, clearing, grubbing, and grading. After your permit is issued, schedule an inspection by calling (206) 684-8900 or online at: http://web1.seattle.gov/DPD/InspectionRequest

Inspectors Notes

Trees are currently tagged and fenced for protection. Oregon and Renton are missing their final asphalt lifts. The curb is not complete at the south end of Renton where the future proposed entrance will be. Site slopes to the East, no structures onsite at this time. No unusual conditions observed.

Seattle City Light Requirements

Contact: Bob Hansen, bob.hansen@seattle.gov

Based on the information provided at this time, it does not appear that SCL has additional requirements to accommondate construction of your project. For electrical service design and connection questions, please refer to "Applicant Next Steps." Be advised that it is your responsibility to seek guidance from SCL should the scope of the project change or should you become aware of proposed construction in the right-of-way. Failure to contact SCL at your earliest convenience could serverely impact your project's scope, schedule and budget. This responsibility rests solely with the applicant.

DPD Drainage Requirements

Contact: Joseph P Berentsen, (206) 684-8613, Joe.Berentsen@seattle.gov

The following requirements are based on the current stormwater and side sewer codes. Major updates to these codes are expected in the fourth quarter of 2009.

Existing Public Drainage Infrastructure

Sanitary sewer main location: Renton Ave. S.

Sanitary sewer main size: 8" Diameter

Storm drainage main location: Renton Ave. S.

Storm drainage main size: 12" Diameter

Drainage

The drainage point of discharge (SMC 22.805.020) is located at: Public storm drain system.

Flow Control Compliance

All new, replaced, and disturbed topsoil shall be amended with organic matter per rules promulgated by the Director prior to completion of the project to improve onsite management of drainage water flow and water quality per SMC 22.805.020.E. Refer to CAM 531, Post Construction Soil Management. For projects with 5,000 square feet or more of new plus replaced impervious surface, a comprehensive drainage control plan and construction stormwater control plan shall be prepared by a licensed engineer.

Parcel-based projects with 7,000 square feet or more of land disturbing activity or 2,000 square feet or more of new plus replaced impervious surface must implement green stormwater infrastructure to infiltrate, disperse, and retain drainage water onsite to the maximum extent feasible without causing flooding, landslide, or erosion impacts per SMC 22.805.020.F. Refer to Director's Rule 19-2009 - Requirements for Green Stormwater Infrastructure to the Maximum Extent Feasible and Director's Rule 17-2009 - Stormwater Manual Vol. III - Stormwater Flow Control and Water Quality. Submit a GSI Calculator per DR 19-2009.

Water Quality

This project site discharges to a water body that requires basic treatment (SMC 22.805.050 B). Based upon the information provided on the Preliminary Application Form pertaining to existing and proposed impervious surfacing this project shall: provide a basic treatment facility that treats the required runoff volume or flow rate from pollution generating surfaces (SMC 22.805.090 B1, B2).

Based upon the information provided on the Preliminary Application Form pertaining to existing and proposed impervious surfacing and proposed site usage this project shall: provide an oil control facility that treats the required runoff volume or flow rate from high use designated pollution generating surfaces (SMC 22.805.090 B.1, B.3).

Wastewater

All homeowners and building owners in King County's service area whose home or building was newly connected to the King County sewer system on or after Feb. 1, 1990 must pay a King County Capacity Charge. Further information is available online at:

http://www.kingcounty.gov/environment/wastewater/capacitycharge.aspx

Permanent and Temporary Dewatering

The footing drain (if part of building plan) point of discharge (DPD DR 3-2006/SPU DR 02-06 VII.H) is located at the following: Public storm drain system.

DPD Land Use Code Requirements

Contact: Craig W Flamme, (206) 233-7223, Craig.Flamme@seattle.gov

Street Requirements

Based on the scope of the proposed project, the following street improvements are required per Chapter 23.53 of the Seattle Municipal Code. Please review Right-of-Way Improvements Manual for design criteria (http://www.seattle.gov/transportation/rowimanual/manual/). Show required street improvements on your "enhanced site plan" at DPD permit application intake. If an SDOT Street Improvement Plan (SIP) is required, please list SDOT project number and SDOT contact name on the enhanced site plan. Street Improvement Plans must be accepted by SDOT prior to DPD permit application intake.

RENTON AVE S

Pavement could be required to be installed or widened in the portion of right-of-way abutting this lot.

Curbs will be required to be installed in the portion of right-of-way abutting this lot.

A concrete sidewalk will be required to be installed in the portion of right-of-way abutting this lot.

Drainage will be required to be installed in the portion of right-of-way abutting this lot. If you need further clarification, contact SDOT for further information or apply for SDOT SIP design guidance (see SDOT CAM 2211).

Street trees shall be provided in the planting strip according to Seattle Department of Transportation Tree Planting Standards. Contact SDOT Urban Forestry (for residential projects: (206) 684-TREE; for all others: (206) 684-5693), to determine species of tree and standards of planting. Please add a note to the site plan showing size, location and species of tree to be planted.

http://www.seattle.gov/transportation/treeplanting.htm.

Landscaping is required to be installed in the planting strips in the right-of-way. Contact SDOT Urban Forestry to determine species of landscaping and standards of planting. For residential projects, call (206) 684-TREE; for all others, call (206) 684-5693). Please add a note to the site plan showing size, location and species of shrubs and groundcover to be planted.

S OREGON ST

Pavement could be required to be installed or widened in the portion of right-of-way abutting this lot.

Curbs will be required to be installed in the portion of right-of-way abutting this lot.

A concrete sidewalk will be required to be installed in the portion of right-of-way abutting this lot.

Drainage will be required to be installed in the portion of right-of-way abutting this lot. If you need further clarification, contact SDOT for further information or apply for SDOT SIP design guidance (see SDOT CAM 2211).

Street trees shall be provided in the planting strip according to Seattle Department of Transportation Tree Planting Standards. Contact SDOT Urban Forestry (for residential projects: (206) 684-TREE; for all others: (206) 684-5693), to determine species of tree and standards of planting. Please add a note to the site plan showing size, location and species of tree to be planted.

http://www.seattle.gov/transportation/treeplanting.htm.

Landscaping is required to be installed in the planting strips in the right-of-way. Contact SDOT Urban Forestry to determine species of landscaping and standards of planting. For residential projects, call (206) 684-TREE; for all others, call (206) 684-5693). Please add a note to the site plan showing size, location and species of shrubs and groundcover to be planted.

SDOT Requirements

Contact: Yohannes Minas, <u>yohannes.minas@seattle.gov</u>

The City of Seattle's Right-of-Way Improvements Manual (ROWIM) and SDOT's Street & Sidewalk Pavement Opening and Restoration (PORR) Director's Rule 2004-02 may be accessed from SDOT's Street Use website at: http://www.seattle.gov/transportation/stuse_docs.htm. Whenever possible, specific reference notation for these two design documents is noted next to the design characteristics below. Be advised that these specific section and chapter references are provided as preliminary guidance only and are not comprehensive in scope.

SDOT Permitting Information

SDOT Project No: 21485

Street Improvement Requirements RENTON AVE S

Other requirements: SHA has been issued a Street Improvement permit.

S OREGON ST

Other requirements: SHA has been issued a Street Improvement permit.

SPU Requirements

Contact: Jennyfer Jacobsen, (206) 684-8766, JacobsJS@seattle.gov

Flow Control Compliance

All new, replaced, and disturbed topsoil shall be amended with organic matter per rules promulgated by the Director prior to completion of the project to improve onsite management of drainage water flow and water quality per SMC 22.805.020.E. For projects with 5,000 square feet or more of new and replaced impervious surface, a comprehensive drainage control plan shall be prepared by a licensed engineer.

Roadway projects with 7,000 square feet or more of land disturbing activity or 2,000 square feet or more of new plus replaced impervious surface must implement green stormwater infrastructure to infiltrate, disperse, and retain drainage water onsite to the maximum extent feasible without causing flooding, landslide, or erosion impacts per SMC 22.805.020.F. Refer to DR GSI to MEF and DR Vol.3.

Stormwater Treatment

This project site discharges to a water body that requires basic treament (SMC 22.805.050 B). Based upon the information provided on the Preliminary Application Form pertaining to existing and proposed impervious surfacing this project shall: provide a basic treatment facility that treats the required runoff volume or flow rate from pollution generating surfaces (SMC 22.805.090 B.1, B.2)

Based upon the information provided on the Preliminary Application Form pertaining to existing and proposed impervious surfacing and proposed site usage this project shall: provide an oil control facility that treats the required runoff volume or flow rate from high use designated pollution generating surfaces (SMC 22.805.090 B.1, B.3)

Water Availability

Contact: INTAKETEAM INTAKETEAM

Your water availability assessment is in progress.

Other Requirements

Owners of residential property occupied by a tenant who will be displaced by housing demolition, substantial rehabilitation, change of use, or removal of use restrictions may need to obtain a Tenant Relocation License. Refer to DPD CAM 123, Seattle's Tenant Relocation Assistance Ordinance, for further information and instructions or call (206) 684-7979.

If your project involves additions or modification to or demolition of an existing building that contains four or more dwelling units or 4,000 square feet or more of non-residential area, and the building is a designated historic landmark or is 50 years old and meets the criteria set forth in SMC 25.12 for landmark designation, SEPA is required. Please contact the Department of Neighborhoods at (206) 684-0228 or www.seattle.gov/neighborhoods/preservation to determine if your building is a designated landmark of if a referral is necessary to determine if the building meets the criteria in SMC 25.12. Refer to CAM 208 for information regarding the application requirements for a SEPA review and CAM 3000 for information regarding landmarks and historic preservation.

Applicant Next Steps

For questions on the permit application process, please contact the Applicant Services Center (ASC) at 206-684-8850.

- 1. Review the requirements in this report.
- 2. Use Client Assistance Memos (CAMs), checklists and standards, and 5 Steps for a Successful DPD Application Submittal (available on the DPD website) for additional information.
- 3. If a SIP is required, **DPD will not accept your application until your SIP application is screened at SDOT.** Allow a minimum of 5 days for screening after application submittal to SDOT.
- 4. Information on requirements for Electric Service Connection (RESC), electric service applications, guidelines and other services can be found on Seattle City Light's website (http://www.seattle.gov/light/newconstruction/). Contact an Electric Service Representative for your electrical service design and connection questions:

North of Denny Way (206) 615-0600 South of Denny Way (206) 386-4200 Large Commercial & Industrial (206) 233-7177 Service Applications (206) 233-APPS (2777)

- 5. If you have additional questions or need additional information, you may request a pre-submittal conference. Call (206) 684-8850 or go to DPD's website (http://www.seattle.gov/dpd/Publications/Forms/Building Permit/default.asp).
- 6. When all issues have been addressed, you may schedule an intake appointment with DPD. **Please bring a copy of this report to your intake appointment.**

The requirements and determinations in this report are based on the details provided by the applicant on the preliminary application form and site plan submitted to DPD. If the scope of your proposed project changes before your DPD intake appointment or SDOT SIP application, the requirements in this report are subject to change. If there are municipal code and ordinance changes prior to your DPD intake, the project must meet the new code requirements. Additional street improvement requirements may be triggered if a permit application for a development project on adjacent property is also undergoing review.